

<u>Ticket #</u>	<u>WO #</u>	<u>Date</u>	<u>Type</u>	<u>Account ID</u>	<u>Account Tag</u>	<u>Description</u>	<u>Resolution</u>
325,360	325360	2021-09-	Service	CMT-1533	1326 West 13th Avenue-Alexander	September 15 2021 - Fire alarm verification and maintenance	FM8 - Provide access to other trades to inspect smoke and fire equipment. Performed with regular monthly maintenance
325,606	325606	2021-10-	Safety Test	MT-1533	1326 West 13th Avenue-Alexander	Perform Electric - Brake - Annual on unit Alexander Tower (State ID:3299) at 1326 West 13th Avenue. This test is performed every 12 months and was last run on 10/16/2020.  This test is under the authority of BCSA	Test completed
332,161	332161	2021-09-	Maintenance	MT-1533	1326 West 13th Avenue-Alexander	HB109-3299 TYPE A - (1208-03) Electric Elevator - Brake Declaration	F.A.V with maintenance
336,528	336528	2021-09-	Service	CMT-1533	1326 West 13th Avenue-Alexander	September Maintenance - FM8 - monthly SEPT 27 - 2021 - Elevator is out of service on the 5th floor with doors open.	FM8 - Repaired the 5th floor relay, tested and left in service.
337,110	337110	2021-09-	Service	CMT-1533	1326 West 13th Avenue-Alexander	September 30, 2021 - Elevator is working intermittently but there is hydraulic fluid all over the machine room and the elevator needs to home on the ground floor.	FM8 - Technician submitted a work order to fix the gearbox leaking. He also talked to Jon Dodge to send a quote to replace pushbuttons.
343,163	343163	2021-10-	Maintenance	MT-1533	1326 West 13th Avenue-Alexander	HB109-3299 October Maintenance - FM8 - monthly	Regular Maintenance Complete
354,415	354415	2021-11-	Maintenance	MT-1533	1326 West 13th Avenue-Alexander	HB109-3299 November Maintenance - FM8 - monthly	Regular Maintenance Complete
357,985	357985	2021-11-	Service	CMT-1533	1326 West 13th Avenue-Alexander	November 18 2021 -Replaced the hall button already but Fifth floor hall button doesnt work - for follow up from John F	FM8 - 6d coil and plate broken temporary connected with 6c car call
365,802	365802	2021-12-	Maintenance	MT-1533	1326 West 13th Avenue-Alexander	HB109-3299 December Maintenance - FM8 - monthly	maintenance
368,017	368017	2021-12-	Service	CMT-1533	1326 West 13th Avenue-Alexander	DEC 10 - 2021 - When you call the elevator from 5th floor it will not respond	FM8 - Replaced the 5th floor relay coil on controller; tested and left in service.
368,516	368516	2021-12-	Service	CMT-1533	1326 West 13th Avenue-Alexander	December 14 2021 - INSTALL PART FOR THE issue is with the 5th floor button.	FM8 - Not able to access the building.
370,019	370019	2021-12-	Service	CMT-1533	1326 West 13th Avenue-Alexander	DEC 22 - 2021 - Elevator entrapment	FM8 - Passengers were released upon the technicians arrival. Requested for a trouble shooter.
370,024	370019	2021-12-	Service	CMT-1533	1326 West 13th Avenue-Alexander	DEC 22 - 2021 - Follow up on Ticket #370019 - Elevator entrapment	FM8 - Tired to reset. Requested for trouble shooter
370,043	370043	2021-12-	Service	CMT-1533	1326 West 13th Avenue-Alexander	December 23 2021 - Elevator out of service.	FM8 - Replaced C coil, burned contacts
370,346	370346	2021-12-	Service	CMT-1533	1326 West 13th Avenue-Alexander	December 24 2021 - Elevator out of service.	FM8 - C contactor little screw blocking the c contactor; taken out; tested and left in service.
377,469	377469	2022-01-	Maintenance	MT-1533	1326 West 13th Avenue-Alexander	HB109-3299 January Maintenance - FM8 - monthly	maintenance and test
381,785	381785	2022-01-	Service	CMT-1533	1326 West 13th Avenue-Alexander	January 19, 2022 - Elevator is out of service.	FM8 - The elevator was running on the technicians arrival. Site is painting the elevator doors. No faults found. Tested and left in service.
384,349	384349	2022-02-	Maintenance	MT-1533	1326 West 13th Avenue-Alexander	HB109-3299 February Maintenance - FM8 - monthly	maintenance and test